

Fred A. Mitchell Jr.
Chief of Department



Fire Business: 978 352-5757
Fire Facsimile: 978 352-5741

TOWN OF GEORGETOWN
Fire Department Headquarters
47 Central Street
Georgetown, Massachusetts 01833-2408

RECEIVED
MAR 12 2019

GEORGETOWN
ZONING BOARD OF APPEALS

March 12, 2019


Georgetown Zoning Board of Appeals
1 Library Street
Georgetown Massachusetts 01833

Re: G. Mello Disposal Corp. Carlton Drive Georgetown Massachusetts

Georgetown Zoning Board of Appeals;

The Fire Department is in full support of the proposed transfer station project on Carlton Drive with the following provisions. First, the facility must meet all Mass DEP regulations for confinement, containment, and runoffs of any hazardous waste/materials. Also, any and all hazardous materials shall be properly stored. The proposed building must meet all existing MGL 527 CMR, Fire Protection System, and NFPA fire codes pertaining to their facilities use. The facility must have a municipally connected fire alarm system. Finally, ensure that the fire department has adequate access to the facility in case of an emergency response. Please feel free to contact me with any question. Thank you.

Regards,


Chief Fred A. Mitchell Jr
Georgetown Fire Department
47 Central Street
Georgetown Massachusetts 01833

Cc: File

Patty Pitari Administrative Assistant Zoning Board of Appeals